

CODE: MBK09-060PA-P1F

ERP: 0135229

Fire Extinguisher 6Kg Dry Powder EXCLUSIVE

Portable

Fire Extinguisher 6Kg Dry Powder ABC 40% with one seam vessel and Pressure Gauge Safety Release Valve. EXCLUSIVE Type/Model: MBK09-060PA-P1F



Characteristics

Capacity	6Kg
Fire performance	43A 233B C
Extinguishing agent	ABC 40% Dry Powder
Operating temperature	-30°C to 60°C
Average discharge time	18.47sec
Test pressure	26bar
Max allowable pressure	18.00bar
Volume of equipment	7.90Lt
Cylinder material	St12
Cylinder height	450 ± 5 mm
Cylinder diameter	160 ± 1.5 mm
Cylinder neck thread	30 x 1,5 mm
Valve material	HPb59-1
Safety valve	22-26 bar
Paint Finish	RAL 3000
Approx. Gross Weight	9.50Kg
Approx. Dimensions	550 x 160 mm
Work pressure at 20°C	15bar
Approx. Discharge Distance	6m
Packing Details	Atomic Carton Box



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: www.mobiak.gr

email: info@mobiak.gr



HEALTH & SAFETY MANAGEMENT SYSTEM
OHSAS 18001:2007
QA-C-510B/12



TÜVRheinland[®]
CERT
ISO 14001



ISO 9001:2008
Cert No 37939



RINA
SERVICE RECOGNITION
11X107101

