

CODE: MBK03-300CA-P1A

ERP: 0129001

Trolley Fire Extinguisher 30Kg CO2

Carbon Dioxide (CO2)

30Kg CO2 Trolley Fire Extinguisher with 40Lt Cylinder with 5m Discharge Hose. > HIGH PRESSURE EPDM Discharge Hose of WP 155bar with Wooden Handle and Flow Control Valve, according to EN853 requirements > HEAVY Duty Carriage and wheels > Valve Protection HANDLE All CO2 Trolley Fire Extinguishers are also available with 8 meter discharge hose upon request



Characteristics

Capacity	30Kg
Fire performance	113B
Extinguishing agent	Carbon Dioxide
Operating temperature	-30°C to 60°C
Average discharge time	63.40sec
Test pressure	300bar
Max allowable pressure	200.00bar
Volume of equipment	40.00Lt
Cylinder material	34CrMo4
Cylinder height	1280 ± 30 mm
Cylinder diameter	229 ± 2.29 mm
Cylinder neck thread	25E
Valve material	HPb59-1
Safety valve	225 ± 22.5 bar
Paint Finish	RAL 3000, RAL 7037
Approx. Gross Weight	103.00Kg
Approx. Dimensions	1350x350x485 mm
Packing Details	Atomic Packing

97/23/EC



ISO 9809 - 1



2010/35/EU (π)

EN1866



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: www.mobiak.gr

email: info@mobiak.gr



Net
HEALTH & SAFETY MANAGEMENT SYSTEM
OHSAS 18001:2007
QA-C-510B/12



TÜV Rheinland[®]
CERT
ISO 14001



ISO 9001:2008
Cert No 37939



RINA
SERVICE RECOGNITION
11X107101



FACTORY: AKROTIRI, CHANIA, P.C.: 73100, TEL.: +30 2821063222, FAX: +30 28210 66260

CENTRAL EXHIBITION: 96-98 M. MPOTSARI str. P.C.: 73136, CHANIA, GREECE, TEL.: +30 28210 91561, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: MAGOULA - ASPROPIRGOS, P.C.: 19300, TEL.: +30 210 4614006, FAX: +30 210 5595986

N.GREECE DISTRIB. CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C.: 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENT. & EAST CRETE DISTRIB. CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE, P.C.: 71601, TEL./FAX: +30 2810 333151

web site: www.mobiak.gr

email: info@mobiak.gr