



APRAGAZ

a.s.b.l.
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

MOBIAK S.A.
96-98 Markou Mpotsari Street
GR – 73136 CHANIA (CRETE)
GREECE

Y/Ref. :
O/Ref. : CHL/MMO/PRODUCT CERTIFICATION/BUILDINGS/MOBIAK

January 15, 2014

APPROVAL CERTIFICATE EN3 – PORTABLE FIRE EXTINGUISHERS

We hereby declare that the hereafter mentioned extinguishers were approved according to the requirements of the EN 3-7 standards and according to the hereafter mentioned tests reports:

Mark	Type	Nominal charge	Achieved fire ratings	EN 3-7 test report No.
MOBIAK	MBK13-060ABF-P1E	6 l premix Eco Dare ABF -30°C/M	21 A - 144 B- 75 F	EN 11301
MOBIAK	MBK13-090ABF-P1E	9 l premix Eco Dare ABF -30°C/M	27 A - 233 B -75 F	EN 11302

The General Manager,

Christian LEPLAT, ir.