



# APRAGAZ

a.s.b.l.  
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels  
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58  
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

MOBIAK S.A.  
96-98 Markou Mpotsari Street  
GR – 73136 CHANIA (CRETE)  
GREECE

Y/Ref. :  
O/Ref. : VDS/BG

Date : October 6, 2021

**APPROVAL CERTIFICATE EN 3-7 – PORTABLE FIRE EXTINGUISHERS FOR BUILDINGS**  
*extension of the approval for modification of constructive detail, higher or other fire rating and type.*

We hereby declare that the hereafter mentioned extinguishers were type approved according to the requirements of the EN3-7 standards, according to the tests reports and with the hereafter mentioned approval number, by extension of the approvals mentioned on the certificate of (date).

Approval No.	Brand	Type	Nominal Charge	Fire ratings achieved	EN 3-7 test report No.
EN3-21/477	MOBIAK	MBK19-LITHIUM-2	2 L AVD (premix)	5 A	EN 12275
EN3-21/478	MOBIAK	MBK19-LITHIUM-6	6 L AVD (premix)	8 A	EN 12276
EN3-21/479	MOBIAK	MBK19-LITHIUM-9	9 L AVD (premix)	13 A	EN 12277

The approval is subject to the continued maintenance of the Quality System of the manufacturer in accordance with the relevant requirements of EN3-10.

The manufacturer is authorized to affix the above mentioned approval number on the marking label of the approved corresponding extinguishers as long as the results of our inspections, periodically made according to the requirements of § 10 of the EN 3-10, are satisfactory.

Nota Bene: additional requirements (i.e. : language of the labels, maintenance requirements, ...) may be made by national regulations and/or quality marks.

Head of Fire Extinguisher Department

Christophe Vanderschriek